

City of Lambertville
18 York Street, Lambertville NJ 08530
Phone: 609-397-0803 ~ Fax: 609-397-2203

Application for One & Two Family Dwelling
Certification of Smoke Detector / Carbon Monoxide Alarm & Portable
Fire Extinguisher Compliance

PLEASE TAKE NOTE, THE INSPECTION FEE HAS CHANGED AND IS
NOW **\$65.00** FOR EACH APPLICATION.

FRANK D'AMORE
Bureau of Fire Prevention

Office Hours: Fridays & Saturday between 1:00 pm to 4:00 pm

1. Complete the attached application and submit it to the Construction Office, with a check in the amount of \$65.00, made payable to the City of Lambertville
2. If an inspection fails, you are required to submit another application and pay an additional fee of \$65.00.
3. Inspections are done on Fridays & Saturdays between 1:00 pm and 4:00 pm. Please contact the office at (609) 397-0803 to check the next available date of inspection.

Thank you for your co-operation.

City of Lambertville
18 York Street, Lambertville NJ 08530
Phone: 609-397-0803 ~ Fax: 609-397-2203

Application for One & Two Family Dwelling
Certification of Smoke Detector / Carbon Monoxide Alarm & Portable
Fire Extinguisher Compliance

Office Use Only:

Date Received: _____

Scheduled Inspection Date: _____

Paid: _____

Payment Method: _____

Effective Immediately – All battery smoke detectors must be the 10-year sealed battery units.
No other detectors other than those listed on the sheet attached will be approved.

Property Address: _____ Block & Lot: _____

Property Owner: _____ Owner's Phone Number _____

Contact Person: _____ Phone #: _____

Closing Date: _____

Email Address: _____

I, _____ certify that I am the owner or an authorized representative of the owner of the dwelling at the above referenced location. I further certify that this dwelling has smoke detector(s) and carbon monoxide detector(s) installed and in working order as stated below:

Number of Stories in Dwelling: _____ Basement: ____ Yes ____ No

Applicant's Signature: _____

Date: _____

CARBON MONOXIDE ALARMS OR DETECTORS

A carbon monoxide alarm or detector should be centrally located outside each separate sleeping area in the immediate vicinity of the bedrooms. Where bedrooms are separated and the audibility of the alarm impaired, more than one unit could be needed. Each alarm or detector should be installed within

City of Lambertville
18 York Street, Lambertville NJ 08530
Phone: 609-397-0803 ~ Fax: 609-397-2203

In one- and two-family or attached single family dwellings subject to the requirements of N.J.A.C. 5:70-2.3, smoke alarms shall be installed as follows:

1. On each level of the premises; and
2. Outside of each separate sleeping area.

The smoke alarms required in (a) above shall be located and maintained in accordance with NFPA 72. The alarms shall not be required to be interconnected.

Ten-year sealed battery-powered single station smoke alarms shall be installed and shall be listed in accordance with ANSI/UL 217, incorporated herein by reference. However, A/C-powered single or multiple-station smoke alarms installed as part of the original construction or rehabilitation project shall not be replaced with battery-powered smoke alarms. The effective date of this subsection shall be January 1, 2019.

1. A/C-powered smoke alarms shall be accepted as meeting the requirements of this section.

Carbon monoxide alarms shall be installed in all dwelling units in buildings in one- and two-family or attached single family dwellings, except for units in buildings that do not contain a fuel-burning device or have an attached garage, as follows:

1. Single station carbon monoxide alarms shall be installed and maintained in the immediate vicinity of the sleeping area(s).
2. Carbon monoxide alarms may be battery-operated, hard-wired or of the plug-in type and shall be listed and labeled in accordance with UL-2034 and shall be installed in accordance with the requirements of this section and NFPA-720.

A portable fire extinguisher shall be installed in accordance with the following:

1. The extinguisher shall be within 10 feet of the kitchen and located in the path of egress;

2. The extinguisher shall be readily accessible and not obstructed from view;

3. The extinguisher shall be mounted using the manufacturer's hanging bracket so the operating instructions are clearly visible;

4. The extinguisher shall be an approved listed and labeled type with a minimum rating of 2A-10B:C and no more than 10 pounds;

The owner's manual or written operation instructions shall be provided during the inspection and left for the new occupant;

The extinguisher shall be serviced and tagged by a certified Division of Fire Safety contractor within the past 12 months or the seller must have a receipt for a recently purchased extinguisher; and

The top of the extinguisher shall not be more than five feet above the floor.